



Total Quality. Assured.

545 E Algonquin Road, Suite H
Arlington Heights, IL 60005 USA

Telephone: 847-439-5667
intertek.com

Published: January 2, 2020
Revised:

Public Notice ID: 19-30
Page 1 of 2

Safety Concern with Intertek Certified Product / Souci de sécurité avec le produit certifié Intertek

Air Handler models AWUF and ACNF

Notification Type:	Safety / Sécurité
Certification Type:	ETL Listed - US and Canada

Notification

Intertek notifies consumers, retailers and distributors of a potential safety concern involving the Intertek Certified products identified below. / Intertek informe les consommateurs, les détaillants et les distributeurs d'une préoccupation potentielle en matière de sécurité impliquant les produits certifiés Intertek identifiés ci-dessous.

Company Identification

Goodman Company, L.P. of Houston, Texas

Product Identification

The recalled products are air handler models AWUF and ACNF, and s have serial numbers beginning with 1511, 1512, or 1601 through 1610. Recall number: 17-103 <https://www.cpsc.gov/Recalls/2017/Goodman-Recalls-Air-Handlers>

Hazard Involved

Goodman has received reports involving six units at two locations of the air handlers remaining powered when the disconnect handles were removed. No injuries have been reported.

What To Do

Usage should be immediately discontinued and returned to the point of purchase. Distributors and retailers should discontinue sales and return inventories to their its suppliers. / L'utilisation doit être immédiatement abandonnée et retournée au point d'achat. Les distributeurs et les détaillants devraient cesser les ventes et les stocks de retour à leurs fournisseurs.

Published: January 2, 2020
Revised:

Public Notice ID:
Page 2 of 2

Photos and Images

Link to CPSC Recall:

